




## TEST CERTIFICATE

### SUMMARY OF TEST RESULTS

<b>NUMBER</b>	<b>0315</b>	<b>DATE</b>	<b>06 /10 / 03</b>
<b>Client' s data:</b>	<b>ALUMIL – MILONAS S.A.</b> Industrial Area Kilkis GR 611 00 KILKIS GREECE		
<b>Product description:</b>	<b>SINGLE SASH DOOR OPENING / TILTING</b>		
<b>Material:</b>	<b>ALUMINIUM</b>		
<b>System :</b>	<b>M 11000</b>		



2190 x 870 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 9A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C5</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.

**MARIANTHI CHATZIANTONIOU**  
TECHNICAL MANAGER

**IOANNIS GKERTSOS**  
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL